

BHAVANI MUNICIPALITY

Water Supply Details

➤	Present Population on 2018	-	41575
➤	Water Demand in MLD @ 90/135LPCD as per UGSS/ Non UGSS town		
	❖ 90/135	-	90
	❖ MLD	-	3.74
➤	Designed Capacity of all WS schemes of the ULB “MLD”		
	❖ TWAD	-	0.00
	❖ ULB	-	<u>4.20</u>
	Total	-	<u>4.20</u>
➤	Quantity received from all schemes “MLD”		
	❖ TWAD	-	0.00
	❖ ULB	-	4.20
	❖ Quantity received (only potable water) from local sources which is pumped to OHT’s and served through Distribution network	} -	----
	Total	-	4.20
➤	Potential (%) of available potable water Quantity of Water supply received Vs water demand	} -	112%
	Remarks	-	No Water Supply issues at Present

Water Supply - HSC Details

➤ Total Property Tax Assessment	-	13014
➤ HSCs Given		
❖ Domestic	-	5032
❖ Commercial	-	112
❖ Industrial	-	---
➤ Total No. of HSCs given as on 10.02.2020	-	5144
➤ % of HSC given	-	39.53%

Water Supply General Data

➤ No. of Hand pumps	-	4
➤ No. of Mini Power pumps	-	76
➤ No. of Power pumps	-	6
➤ No. of OHT	-	5
➤ No. of Sump	-	--
➤ Length of Pumping Main in Km	-	3.90
➤ Length of Distribution main in km	-	35.80

- ---